


- NOTA :
- Panou perete exterior =80 vata minerala RAL 9010EXT/9002INT;
 - Panou acoperis=80 vata minerala RAL 9002;
 - Inchidere acoperis=80 ;

- LEGENDA
- HSI 150 D3/60
 - HSI 90

Dimensiuni de Gabarit :
 H=3380 mm ; L=8900 mm ; D=2700 mm.



Furnizor: SC ELECTROTEHNO SRL		Client:	
Ci: 5463.1		Contract :	
Produc: PTPA 1 (2) 2x630 KVA;10/0,4KV		Obiectiv:	
Cantitate: 1	Cod doc.: 5463.1_LYT	PI. 1/1	
Nume doc.: Amplasare ECHIPAMENTE		Data: 21.11.2016	
Proiectat: Andries I.	Verificat: Radu Petru	Revizia:0	

- GREUTATI :
- CABINA 4.5 tone ;
 - ACOPERIS 1.1 tone;
 - TDRI 2x0.65 tone;
 - CELULE 6x0.15 tone;
 - TRAFD 2x2.15 tone;
- GREUTATE CABIN (fara CUVA) 12,1 tone
 GREUTATE CUVA BETON 8,9 tone ;
 TOTAL 21,0 tone